

C-16

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2022 / School / WZ / 1170

Dated: 20/10/22

FIRE SAFETY CERTIFICATE

Certified that Mother Khazani Convent School located at Mungeshpur, Delhi-110039 comprised of Ground+One upper floor owned/occupied by Mother Khazani Convent School was issued fire safety certificate vide letter no. F-6/DFS/MS/2019/WZ/197 dated-28/01/2019. The premises was inspected by the officer concerned of this department on dated 10.10.2022 in the presence of Miss Sarita (Principal) and found that the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Circular issued by Director of Education letter dated 01/03/2011 and that the building / premises is fit for occupancy of Class B (Educational) with effect from 20/10/22 for a period of three years, subject to the compliance of the conditions mentioned below.

Issued on20/10/22..... at New Delhi



(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.
2. The Principal, Mother Khazani Convent School, Mungeshpur, Delhi-110039.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in


PRINCIPAL
MOTHER KHAZANI CONVENT SR SEC. SCHOOL
MUNGESHPUR - DELHI - 110039
AN ISO - 9001-2001 Certified Institution

INSPECTION REPORT

1. Name & address of the building	Mother Khazam Convent School, Mungeshpur, Delhi-110039.
2. Type of Occupancy	Educational
3. Building Comprised	Ground + First Floor
4. Type of Case	Renewal
5. Details of Previous NOC	Letter No. F.6/DIFS/MS/2019/WZ/197 Dated-28/01/2019
6. Fire Safety directives letter No	Dir of Edu. Cir dated 01.03.2011.
7. Date of inspection	10/10/2022
8. Name of Inspecting Officer	ADCO, R K Sinha
9. Name and designation of officers From the building side	Smt. Sarita (Principal)
10. Year of Construction	2005
11. Applicant's letter No.	Nil. Dated-29/09/2022

No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	NA	NA	NA
	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			MR
	• Upper Floors	02	03	NA
	• Basements	NA	NA	MR
	b. Width of staircases	1.50 m each	2 m, 1.50 m & 1.25 m	NA
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00 m	Provided	MR
	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA

ll

Sarita
PRINCIPAL
MOTHER KHAZANI CONVENT SR SEC. SCHOL
MUNGESHPUR - DELHI - 110039
AN ISO : 9001-2001 Certified Institution

N-15

	12 n/c per hour	Natural Ventilated	MR
• Upper floors			
Fire Extinguishers			MR
• Total numbers	13	14	MR
• Types	ABC	ABC/CO2	MR
• IS marking	Yes	Yes	MR
First-Aid Hose Reels			NA
• Total numbers on each floor	NA	NA	NA
• Length of hose reel hose	NA	NA	NA
• Nozzle diameter	NA	NA	NA
Automatic fire detection and alarming system			NA
• Type of detectors	NA	NA	NA
• Location of Main Panel	NA	NA	NA
• Location of Repeater Panel	NA	NA	NA
• Alternate source of power	NA	NA	NA
• Hooters' Location	NA	NA	NA
MOEFA	NA	NA	NA
Public Address System	NA	NA	NA
Automatic Sprinkler System			NA
• Basement	NA	NA	NA
• Ground Floor	NA	NA	NA
• Sprinkler above false ceiling	NA	NA	NA
Internal Hydrants			NA
• Size of riser/down-comer	NA	NA	NA
• Number of hydrants per floor	NA	NA	NA
• Hose Box	NA	NA	NA
Yard Hydrants			NA
• Total number of hydrants	NA	NA	NA
• Hose Box	NA	NA	NA
Pumping Arrangements			NA
• Ground Level	NA	NA	NA
➤ Discharge of main Pump	NA	NA	NA
➤ Head of Main pump	NA	NA	NA
➤ Number of main pumps	NA	NA	NA
➤ Jockey Pump out put	NA	NA	NA
➤ Jockey pump head	NA	NA	NA
➤ Standby Pump out put	NA	NA	NA
➤ Standby Pump Head	NA	NA	NA
➤ Auto Starting/Manual Stopping	NA	NA	NA

Or


Principal
 MOTHER KHAZANI CONVENT SR SEC. SCHOOL
 MUNGESHPUR - DELHI - 110039
 AN ISO - 9001-2001 Certified Institution

	Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
	Captive Water Storage for fire fighting	NA	NA	NA
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
	Exit Signage.			
	Provision of Lifts.	NA	NA	NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
7.	Standby power supply			
8.	Refuge Area.	NA	NA	NA
	➤ Total Area	NA	NA	NA
	➤ Location			
9.	Fire Control Room	NA	NA	NA
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

Principal
MOTHER KHAZANI CONVENT SR SEC. SCHOL
MUNGESHPUR - DIST. HI. - 110039
AN ISO - 9001-2008 Certified Institution

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOF circular dated 01.03.2011 it is recommended to renew the Fire Safety Certificate issued vide letter no.F-6/DFS/MS/2019/WZ/197.


ADO(BW)
13/10/22


Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.


DO (NPS) on leave

DO (NPS)


17/10/22


ADO/BW F-T letter in progress for compliance

DO (NPS)


19/10/22


ADO(BW)
18/10/22

MS 1 all


PRINCIPAL
MOTHER KHAZANI CONVENT SR SEC. SCHOOL
MUNGESHPUR - DELHI - 110039
AN ISO 9001:2001 Certified Institution