

DELHI JAL BOARD: GOVT. OF NCT OF DELHI
OFFICE OF THE EXECUTIVE ENGINEER (RWH/GWC)
ROOM NO. 209, VARUNALAYA PHASE-I
KAROL BAGH, NEW DELHI - 110005

23558264

No./DJB/EE(RWH/GWC)/2019/ 992

DATED: 13/03/19

To,

Principal,
Mother Khazani Convent School,
Mungeshpur, Delhi-39

Subject:-Regarding adequacy of rain water harvesting system at Mother Khazani Convent School, Mungeshpur, Delhi-39.

Sir/Madam,

The above said unit has been inspected by Joint Inspection Team on dated 11.03.2019, constituted by Hon'ble NGT in O.A. No. 217/2016. It was found that three Nos. RWH pits with two Nos. old recharge wells are existing at site.

The existing RWH structures are adequate to harvest the roof top run-off for catchment area of above said unit. The RWH structure was found to be functional at the time of inspection.

You are advised to keep the existing RWH system neat & clean & maintain the same periodically. Rain Water conveyance system shall be duly kept connected to RWH pits and filter media shall be maintained and kept neat & clean, as per DJB norms and over flow shall always remain connected to municipal drain.

Princy
PRINCIPAL
MOTHER KHAZANI CONVENT SR SEC SCHOOL
MUNGESHPUR - DELHI - 110039
AN ISO 9001-2001 Certified Institution

EE
EE (RWH/GWC)
EE (G W CELL)
DELHI JAL BOARD
VARUNALAYA BHAWAN,
JHANDEWALLA, N.D.-05